

CLECO POWER LLC

BRAME ENERGY CENTER



CCR ANNUAL INSPECTION

FLY ASH POND

JANUARY 2023

Providence Engineering and Environmental Group LLC
1201 Main Street
Baton Rouge, LA 70802
(225) 766-7400
www.providenceeng.com
Providence Project No: 002-308



TABLE OF CONTENTS

<u>Section</u>	<u>Page</u>
1.0 GENERAL INFORMATION.....	1-1
2.0 QUESTIONS FOR OWNER’S REPRESENTATIVE	2-1
3.0 PHYSICAL DAM FEATURES - RESERVOIR.....	3-1
4.0 PHYSICAL DAM FEATURES - INTAKE WORKS.....	4-1
5.0 PHYSICAL DAM FEATURES - OUTLET WORKS.....	5-1
6.0 SLOPE PROTECTION - EXTERIOR SLOPES	6-1
7.0 SLOPE PROTECTION - INTERIOR SLOPES	7-1
8.0 SLOPE PROTECTION - ABUTMENT/ TOE	8-1
9.0 SURFACE IMPOUNDMENT CREST	9-1
10.0 PHYSICAL DAM FEATURES - SPILLWAY	10-1
11.0 DOCUMENTATION REVIEW.....	11-1

LIST OF APPENDICES

Appendix

- A Photograph Log
- B P.E. Certification

SECTION 1.0

GENERAL INFORMATION

ANNUAL CCR SURFACE IMPOUNDMENT INSPECTION			
Facility Name:		Cleco Brame Energy Center	
Address:		275 Rodemacher Rd. Lena, LA	
Surface Impoundment Name :	Fly Ash Pond	Owner:	Cleco Power LLC
Surface Impoundment ID:	P-0005R1	Operator:	Cleco Power LLC
Nearest City:	Boyce	Parish:	Rapides
Inspector:		Gary J. Leonards, P. E.	
Company:		Providence Engineering & Environmental Group LLC	
Date of Inspection:		12/7/2022	
Weather at Time of Inspection:		Partly Cloudy, Cool	
DESCRIPTION OF THE OPERATION OF THE SURFACE IMPOUNDMENTS:			
<p>The Brame Energy Center's Bottom Ash and Fly Ash surface impoundments are designed to accept the coal combustion residual (CCR) byproducts derived from burning of the Unit 2 coal for the generation of electricity. Cleco ceased placement of CCR into the Fly Ash Pond prior to April 11, 2021. The ponds are classified by the Louisiana Department of Environmental Quality (LDEQ) as Type I Surface Impoundments. Water from the Fly Ash surface impoundment is pumped into the Bottom Ash impoundment which discharges by means of three pumps that discharge the wastewater through the outlet pipe on the western end of the pond. This water discharges into Lake Rodemacher via LPDES outfall 401, thence to Bayou Jean de Jean via LPDES outfall 001, then to the Red River. The minimum levee elevation for the Bottom Ash impoundment is 106 feet NAVD 88. To determine the maximum storage capacity, Providence assumed a freeboard of three feet to the top of the impoundment. The bottom elevation of the Bottom Ash Pond as noted in the solid waste permit application is 85 feet MSL. The maximum capacity of this impoundment, with a freeboard of three feet, is approximately 760.5 acre-feet.</p> <p>The minimum levee elevation for the Fly Ash impoundment is 105 feet NAVD 88. The bottom elevation of the Fly Ash Pond as noted in the solid waste permit application is 85 feet MSL. The permitted capacity of this impoundment is 460.0 acre-feet.</p>			
1.0 GENERAL INFORMATION			
Owner Contact:	Elizabeth Lee	Phone:	318-793-1194
Plant Manager:	George Broussard	Phone:	318-793-1200
Dam Status:	Operational	Year Built:	1982
Latitude:	31° 23.67' N	Longitude:	92° 42.00' W
Dam Size:	617.1 acre-feet (3' Freeboard)		
Bottom of Pond Elevation Information:	85 ft. MSL	Top of Dike Elevation:	105 ft. NAVD 88
Low Operating Level Elevation:	86 ft. NAVD 88	High Operating Level Elevation:	92 ft. NAVD 88
High Operating Level Storage:	254.1 acre-feet @ elevation 92.0 ft. NAVD 88		
Maximum Storage:	460.0 acre-feet (Permitted)		
Maximum Surface Impoundment Area:	43.3 Acres		
Offsite Drainage Area:	Discharges to Bottom Ash Pond		
Spillway Type:	None, Pumped through discharge pipe to Bottom Ash Pond		

SECTION 2.0

QUESTIONS FOR OWNER'S REPRESENTATIVE

2.0 QUESTIONS FOR OWNER'S REPRESENTATIVE	
Construction Plans Available?	<input checked="" type="checkbox"/> Yes <input type="checkbox"/> No
Site Facility Map Available?	<input checked="" type="checkbox"/> Yes <input type="checkbox"/> No
Operations and Maintenance Manual Available?	<input checked="" type="checkbox"/> Yes <input type="checkbox"/> No
Emergency Action Plan Available?	<input checked="" type="checkbox"/> Yes <input type="checkbox"/> No
Recent Modification or Improvements?	Water removal in preparation of final closure
Are Routine Inspections Completed?	<input checked="" type="checkbox"/> Yes <input type="checkbox"/> No
Is Routine Maintenance Completed?	<input checked="" type="checkbox"/> Yes <input type="checkbox"/> No
Is There Vehicle Access to the Pond?	<input checked="" type="checkbox"/> Yes <input type="checkbox"/> No
Is Access Available During Heavy Rains?	<input checked="" type="checkbox"/> Yes <input type="checkbox"/> No
Are Routine Inspection Logs Kept On-site?	<input checked="" type="checkbox"/> Yes <input type="checkbox"/> No
Offsite Drainage Area:	Discharges to Bottom Ash Pond
Spillway Type:	None, Pumped through discharge pipe

SECTION 3.0

PHYSICAL DAM FEATURES - RESERVOIR

3.0 PHYSICAL DAM FEATURES – RESERVOIR:	
Staff Gauge Type:	Level Gauge Indicator
Staff Gauge Elevation at Time of Inspection:	88.0 ft. NAVD 88
Normal Operating Elevation:	88 ft. NAVD 88
Typical Operation:	Discharges to Bottom Ash Pond
Are there any visible swirls?	<input type="checkbox"/> Yes <input checked="" type="checkbox"/> No
If yes, describe (size, location, etc.)	
Is there excessive CCR buildup in the surface impoundment?	<input type="checkbox"/> Yes <input checked="" type="checkbox"/> No
If yes, describe (size of area, location, severity, etc.)	
Approximate volume of Impounded water at time of inspection:	108.9 acre ft.
Approximate volume of CCR at time of inspection:	526,125 cubic yards
Findings:	The reservoir was inspected and appeared to be in satisfactory condition. No corrective actions are required at this time.
Other observations on the reservoir:	None

SECTION 4.0

PHYSICAL DAM FEATURES - INTAKE WORKS

4.0 PHYSICAL DAM FEATURES – INTAKE WORKS:	
Number of Intakes:	None
Description (1):	NA
Size and Type:	NA
Control:	NA
Can Flow be Shutoff or Bypassed:	<input type="checkbox"/> Yes <input type="checkbox"/> No <input checked="" type="checkbox"/> NA
Is the in-flow piping free of debris and otherwise unobstructed?	<input type="checkbox"/> Yes <input type="checkbox"/> No <input checked="" type="checkbox"/> NA
If no, describe (type of debris, reason for obstruction, etc.)	
Describe the quality of discharge from hydraulic structure (turbidity, depth, etc.)	NA
Findings:	NA
Other observations on the intake works:	NA

SECTION 5.0

PHYSICAL DAM FEATURES - OUTLET WORKS

5.0 PHYSICAL DAM FEATURES – OUTLET WORKS:	
Number of Outlets:	One
Outlets/Culvert Pipe Sizes:	6 Inches
Type of Pipes:	HDPE
Control:	Manual, Monitored Daily
Can Flow be Shutoff or Bypassed:	<input checked="" type="checkbox"/> Yes <input type="checkbox"/> No
Describe the overall condition of the hydraulic structure: (Check all that apply)	<input checked="" type="checkbox"/> Functioning Normally <input type="checkbox"/> Not Functional <input type="checkbox"/> Deteriorated <input type="checkbox"/> Damaged <input type="checkbox"/> Adequate <input type="checkbox"/> Inadequate Other:(describe)
Is there evidence of erosion around the hydraulic structure?	<input type="checkbox"/> Yes <input checked="" type="checkbox"/> No
If yes, describe (size of area, location, severity, etc.)	
Is the hydraulic structure outlet flowing freely and unobstructed?	<input checked="" type="checkbox"/> Yes <input type="checkbox"/> No
If no, describe (type of debris, reason for obstruction, etc.)	
Describe the quality of discharge from the hydraulic structure (turbidity, depth, etc.)	The Fly Ash Pond was not discharging into the Bottom Ash Pond at the time of inspection.
Findings:	The outlet works were inspected and appeared to be in satisfactory condition. No corrective actions are required at this time.
Other observations on the outlet works:	None

SECTION 6.0

SLOPE PROTECTION - EXTERIOR SLOPES

6.0 SLOPE PROTECTION – EXTERIOR SLOPES:	
Describe the vegetation on the exterior slope: (Check all that apply)	<input type="checkbox"/> Recently Mowed <input checked="" type="checkbox"/> Good Cover <input type="checkbox"/> Sparse <input type="checkbox"/> Other: (describe)
Is there any erosion on the exterior slope?	<input type="checkbox"/> Yes <input checked="" type="checkbox"/> No
If yes, describe (size of area, location, severity, etc.)	
Is there any erosion protection on the exterior slopes? (e.g. riprap, other)	<input type="checkbox"/> Yes <input checked="" type="checkbox"/> No
If yes, describe (riprap - adequate, inadequate, etc.)	
Are there any Crack/Rills Observed?	<input type="checkbox"/> Yes <input checked="" type="checkbox"/> No
If yes, describe (size of area, location, severity, etc.)	
Are there any Sinkholes Observed?	<input type="checkbox"/> Yes <input checked="" type="checkbox"/> No
If yes, describe (size of area, location, severity, etc.)	
Are there any trees on the slopes?	<input type="checkbox"/> Yes <input checked="" type="checkbox"/> No
If yes, describe (type of vegetation, size, location, etc.)	
Findings:	The exterior slope was inspected and appeared to be in satisfactory condition.
Other observations on the exterior slopes:	None

SECTION 7.0

SLOPE PROTECTION - INTERIOR SLOPES

7.0 SLOPE PROTECTION – INTERIOR SLOPES:	
Describe the vegetation on the interior slopes: (Check all that apply)	<input type="checkbox"/> Recently Mowed <input checked="" type="checkbox"/> Good Cover <input type="checkbox"/> Sparse <input type="checkbox"/> Other: (describe)
Is there any erosion on the interior slope?	<input type="checkbox"/> Yes <input checked="" type="checkbox"/> No
If yes, describe (size of area, location, severity, etc.)	
Is there any erosion protection on the interior slopes? (e.g. riprap, other)	<input type="checkbox"/> Yes <input checked="" type="checkbox"/> No
If yes, describe what type and it's condition (riprap - adequate, inadequate, etc.)	
Are there any Crack/Rills Observed?	<input type="checkbox"/> Yes <input checked="" type="checkbox"/> No
If yes, describe (size of area, location, severity, etc.)	
Are there any Sinkholes Observed?	<input type="checkbox"/> Yes <input checked="" type="checkbox"/> No
If yes, describe (size of area, location, severity, etc.)	
Findings:	The interior slope was inspected and appeared to be in satisfactory condition.
Other observations on the interior slopes:	None

SECTION 8.0

SLOPE PROTECTION - ABUTMENT/ TOE

8.0 SLOPE PROTECTION – ABUTMENT/TOE:	
Describe the vegetation on the Abutment/Toe: (Check all that apply)	<input type="checkbox"/> Recently Mowed <input checked="" type="checkbox"/> Good Cover <input type="checkbox"/> Sparse <input type="checkbox"/> Other: (describe)
Is there any erosion on the abutment/toe?	<input type="checkbox"/> Yes <input checked="" type="checkbox"/> No
If yes, describe (size of area, location, severity, etc.)	
Is there any erosion protection on the abutment/toe? (e.g. riprap, other)	<input type="checkbox"/> Yes <input checked="" type="checkbox"/> No
If yes, describe what type and it's condition (riprap - adequate, inadequate, etc.)	
Are there any Crack/Rills Observed?	<input type="checkbox"/> Yes <input checked="" type="checkbox"/> No
If yes, describe (size of area, location, severity, etc.)	
Is there any Seepage Observed:	<input type="checkbox"/> Yes <input checked="" type="checkbox"/> No
If yes, describe (size of area, location, severity, etc.)	
Findings:	The abutment/toe was inspected and appeared to be in satisfactory condition. No corrective actions are required at this time.
Other observations on the abutment/toe:	None

SECTION 9.0

SURFACE IMPOUNDMENT CREST

9.0 SURFACE IMPOUNDMENT CREST:	
Describe the vegetation on the crest: (Check all that apply)	<input type="checkbox"/> Recently Mowed <input checked="" type="checkbox"/> Good Cover <input type="checkbox"/> Sparse <input checked="" type="checkbox"/> Other: (describe) Gravel
Is there a road or driveway on the crest?	<input checked="" type="checkbox"/> Yes <input type="checkbox"/> No
If yes, describe (good condition, numerous cracks, etc.)	Good Condition
Are there any ruts, depressions, or holes on the crest?	<input type="checkbox"/> Yes <input checked="" type="checkbox"/> No
If yes, describe (size, location, etc.)	
Are there any cracks on the crest?	<input type="checkbox"/> Yes <input checked="" type="checkbox"/> No
If yes, describe (length and width, location and direction of cracking, etc.)	
Are there any trees or other undesired vegetation on the crest?	<input type="checkbox"/> Yes <input checked="" type="checkbox"/> No
If yes, describe (size, location, etc.)	
Are there any sinkholes?	<input type="checkbox"/> Yes <input checked="" type="checkbox"/> No
If yes, describe (size, location, etc.)	
Findings:	The crest was inspected and appeared to be in satisfactory condition. No corrective actions are required at this time.
Other observations on the crest:	None

SECTION 10.0

PHYSICAL DAM FEATURES - SPILLWAY

10.0 PHYSICAL DAM FEATURES – SPILLWAY:	
Type:	None - Pumped through discharge pipe
Slope Protection:	NA
Approach:	NA
Erosion:	NA
Vegetation:	NA
Findings:	NA
Other observations on the spillway:	NA

SECTION 11.0

DOCUMENTATION REVIEW

11.0 DOCUMENTATION REVIEW:	
Weekly Inspections Reviewed:	<input checked="" type="checkbox"/> Yes <input type="checkbox"/> No
Findings: Vegetation maintenance.	
Monthly Instrument Inspections Reviewed:	<input checked="" type="checkbox"/> Yes <input type="checkbox"/> No
Findings: No Issues.	
Groundwater Monitoring:	Monitoring wells are in-place for routine monitoring.
Drawings Reviewed:	<input checked="" type="checkbox"/> Yes <input type="checkbox"/> No
Are there any changes in the geometry of the surface impoundment structure since the previous inspection?	<input type="checkbox"/> Yes <input checked="" type="checkbox"/> No <input type="checkbox"/> NA
If yes, describe (size, location, etc.)	
Other observations:	None

APPENDIX A
PHOTOGRAPH LOG

Site Name: Brame Energy Center – Fly Ash Pond

Site Location: Lena, Rapides Parish, LA

Date: December 7, 2022

Fly Ash Pond

Direction:

Easterly

Comments:

Interior slope of northern levee.



Fly Ash Pond

Direction:

Westerly

Comments:

Pump system in Fly Ash Pond that pumps discharge water into the Bottom Ash Pond and Western interior levee slope.



Site Name: Brame Energy Center – Fly Ash Pond

Site Location: Lena, Rapides Parish, LA

Date: December 7, 2022

Fly Ash Pond

Direction:

Easterly

Comments:

Crest along the northern levee and exterior slope.



Fly Ash Pond

Direction:

Westerly

Comments:

Northern exterior levee slope.



Site Name: Brame Energy Center – Fly Ash Pond

Site Location: Lena, Rapides Parish, LA

Date: December 7, 2022

Fly Ash Pond

Direction:

Westerly

Comments:

Interior slope of northern levee.



Fly Ash Pond

Direction:

Westerly

Comments:

Interior slope of eastern levee.



Site Name: Brame Energy Center – Fly Ash Pond

Site Location: Lena, Rapides Parish, LA

Date: December 7, 2022

Fly Ash Pond

Direction:

Northerly

Comments:

Exterior slope of eastern levee.



Fly Ash Pond

Direction:

Northerly

Comments:

Interior slope of southern levee.



Site Name: Brame Energy Center – Fly Ash Pond

Site Location: Lena, Rapides Parish, LA

Date: December 7, 2022

Fly Ash Pond

Direction:
Northeasterly

Comments:
Interior slope on eastern levee.



Fly Ash Pond

Direction:
Westerly

Comments:
Interior slope on southern levee.



APPENDIX B
P.E. CERTIFICATION

